



## TRANSMISSION CORPORATION OF ANDHRA PRADESH LIMITED

From:  
Chief Engineer  
Construction  
APTRANSCO  
Vidut Soudha,  
Hyderabad.

To  
M/s AK Power Industries Pvt Ltd  
Plot No.30, Shrutineer  
23/2/1/1, Bhagaban Chatterjee Lane  
Howrah-711101(W.B)

Lr No:CE/Const-I/DE/Designs/D.No.391/2011, Dt. 12.2011

Sir,

Sub: M/s AK Power Industries Pvt Ltd-Howrah – Approval of unit— For supply of tower parts & Bolts &nuts, Line &SS Hard ware up to 220kv Class – Communicated – Regarding.

Ref: Lr.No.nil dt 9/11/2011

With reference to your letter cited above M/s AK Power Industries Pvt Ltd Howrah is approved to supply galvanized tower parts, Bolts &nuts and Line &SS hard ware up to 220kv Class to APTRANSCO Projects through the agencies executing the projects of 132kv & 220kv on turnkey basis subject to fulfilling the following terms and conditions.

- 1) M/s AK Power Industries Pvt Ltd Howrah shall procure steel angles/coils from SAIL, VSP, TISCO & ISCO. If certain angles are not available with above four main producers, you may procure the angles from other producers approved by APTRANSCO subject to two stage inspections i.e., angles before fabrication and after fabrication shall be invariably carried out by APTRANSCO. In case of line & ss hard ware relevant tests to be conducted as per IS 2486/IEC -120 standards before making supplies to AP Transco Projects through other turnkey contractors. The supplies are accepted if the hard ware is in line with AP Transco specifications.
- 2) You should submit a Bank Guarantee of Rs.10.0 lakhs towards performance guarantee of the materials both tower parts and hard ware supplied to APTRANSCO and shall be valid for 2 years with a claim period of 6 months.
- 3) You shall submit Manufacturing Quality Assurance Plan of materials for fabrication of towers and Line &SS Hard ware and Bolts &Nuts.
- 4) Proto assembly of towers is essential to proceed with mass fabrication.

Yours faithfully,

**CHIEF ENGINEER  
CONSTRUCTION-I**

Copy to:

The Superintending Engineer/PM-II/Construction-I/APTRANSCO/VS  
The Superintending Engineer/PM-II/Construction-II/APTRANSCO/VS

## CHHATTISGARH STATE POWER TRANSMISSION CO. LTD.

(A Govt. of Chhattisgarh undertaking) (A successor Company of CSEPT)  
DANGANIYA, RAIPUR -- 492 013 (CG)

Ph.No.-0771-2574245/40

Fax-0771-2574246

No. 02-04/SS1/vendor/ 0268

Raipur. dtd. 20-04-2012

To,

The Chief Engineer (EITC),  
CSPDCL, Raipur.

Sub: **Addition of vendors for supply of equipments in the approved vendor list.**

\*\*\*\*\*

A supplementary vendor list is enclosed here with for publication under the head 'vendor list' in CSPDCL's website.

Encl: As above

Chief Engineer (Transmission)  
C.S. Power Transmission Co. Ltd., Raipur



## GETCO



### GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED

Regd. Office: Sardar Patel Vidyut Bhavan, Race Course, VADODARA – 390 007.

Telephone No.(0265)2310582/83/84/85,(D)2327482, Fax no. 2339066 (D)

Fax- Control room 2337918/2338164

Website: [www.getco.gujarat.com](http://www.getco.gujarat.com), email: [ceprojects.getco@gegmail.com](mailto:ceprojects.getco@gegmail.com)

Ref.CE(P)/Proc/Vender Regn/III/A.k.Power/ 5091 Date: 14.8.2012

REGISTRATION NO: 470

**By RPAD**

To,  
M/s. A.K. Power Industries Pvt. Ltd.  
Unit – II, Howrah – Amta Road, Kantalia,  
Nibra, Howrah – 711 409

Subject: Registration as a Vendor.

Ref : Your letter No. AKPI/GETCO/11-12/1862 DTD. 02.02.12.

Dear Sirs,

With reference to the above, it is to inform you that subsequent to the factory inspection carried out by Mr. P.N. Chauhan, EE(TR), Radhanpur, on 07 & 08.04.12 factory located at Unit – II, Howrah – Amta Road, Kantalia, Nibra, Howrah, it is decided to enroll your firm as 'New Approved Vendor' for Supply and Manufacturer of following item:

1. Transmission line tower up to 220 KV
2. Sub station structure up to 220 KV

The above approval is subject to the following conditions.

1. The registration shall /be applicable to GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED only.
2. The registration is subject to having valid license for documents related to manufacture / supply of material. Please note that it shall be renewed sufficiently in advance before expiry of valid documents submitted by you and will have to submit with the tender documents.
3. The registration will not apply to any of your branches / offices.
4. The registration on the approved list does not guarantee the award of contracts.

Contd.



## GETCO



### GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED

Regd. Office: Sardar Patel Vidyut Bhavan, Race Course, VADODARA – 390 007.

Telephone No.(0265)2310582/83/84/85,(D)2327482, Fax no. 2339066 (D)

Fax- Control room:2337918/2338164

Website: [www.getco.gujarat.com](http://www.getco.gujarat.com), email: [ceprojects.getco@gegmail.com](mailto:ceprojects.getco@gegmail.com)

Ref. CE(P)/Proc/Vender Regn/III/A K Power Indus./ 3334 Date: 29.3.2013

**By RPAD**

REGISTRATION NO: 495

14-4-13

To,  
M/s.A K Power Industries Pvt. Limited  
Unit No.1, Howrah – Amta Road, Kantalia, Nibra,  
HOWRAH : 711 409

Subject: Registration as a Vendor.

Ref : Party's letter No. AKPI/GETCI/11-12/1858 dtd. 2.2.2012

Dear Sirs,

With reference to the above, it is to inform you that subsequent to the factory inspection carried out by Mr. P C Mehta, EE(Trans), Viramgam, inspection done on 05 & 06.03.2013 factory located at Unit No.1, Howrah – Amta Road, Kantalia, Nibra, HOWRAH : 711 409. it is decided to enroll your firm as 'New Approved Vendor' for Supply and Manufacturer of following item:

1. Hardware & Accessories for ACSR Dog, Panther & Zebra Conductor.
  - a) Single Suspension & Tension
  - b) Double Suspension and Tension
  - c) Mid Span Joint
  - d) Repair Sleeve
  - e) PA Rod
2. Hardware & Accessories suitable for 7/3.15 Earthwire
  - a) Suspension Clamp
  - b) Tension Clamp
  - c) Cross – by clip
  - d) Earthbond
  - e) Mid Span Joint.

The above approval is subject to the following conditions.

1. The registration shall /be applicable to GUJARAT ENERGY TRANSMISSION CORPORATION LIMITED only.
2. The registration is subject to having valid license for documents related to manufacture / supply of material. Please note that it shall be renewed sufficiently in advance before expiry of valid documents submitted by you and will have to submit with the tender documents.

Contd..

## JHARKHAND STATE ELECTRICITY BOARD

Engineering Building, H.E.C., Dhurwa, Ranchi - 834 004

**Fax No. - 0651 - 2400799**

Letter No. 46.....C.E. (T)/J.S.E.B  
C.E. (Trans.)/J.S.E.B/637/07 (Part - IV)

Dated 29/1/13.....

From, **Er. R. N. Tiwary**  
Chief Engineer (Transmission)

To, **M/s A. K. Power Industries Pvt. Ltd.,**  
Shrutineer, 23/2/1/1, Bhagaban Chatterjee Lane,  
Howrah - 711 101 (West Bengal)

**Fax No. - 033 - 26775147**

**Sub: Enlistment of vendor for supply of Galvanised Transmission Towers with their accessories and Gantry Structures (Sub-Station) upto 400 kV class for three years.**


Ref: Your request letter ref: AKPI/ JSEB/ HW/ 12-13/ 967 dated 16.01.2013.

Dear Sir,

With reference to your above mentioned letter, I am pleased to inform you that your name (firm) is approved for enlistment in the list of approved vendors of J.S.E.B. for supply of Galvanised Transmission Towers with their accessories and Gantry Structures (Sub-Station) upto 400 kV class for our transmission line/ sub-stations both for direct supplies & for supply through turnkey contractors for three years.

This has got approval of Engineer-in-Chief.

Yours faithfully

  
(R. N. Tiwary)  
Chief Engineer (Transmission)

## JHARKHAND STATE ELECTRICITY BOARD

Engineering Building, H.E.C., Dhurwa, Ranchi - 834 004

**Fax No. - 0651 - 2400799**

Letter No. 47.....C.E. (T)/J.S.E.B  
C.E. (Trans.)/J.S.E.B/637/07 (Part - IV)

Dated 29/1/13.....

From, **Er. R. N. Tiwary**  
Chief Engineer (Transmission)

To, **M/s A. K. Power Industries Pvt. Ltd.,**  
Shrutineer, 23/2/1/1, Bhagaban Chatterjee Lane,  
Howrah - 711 101 (West Bengal)

**Fax No. - 033 - 26775147**

**Sub: Enlistment of vendor for supply of hardware for insulator, Conductor and Earth Wire accessories for three years.**


Ref: Your request letter ref: AKPI/ JSEB/ HW/ 12-13/ 968 dated 16.01.2013.

Dear Sir,

With reference to your above mentioned letter, I am pleased to inform you that your name (firm) is approved for enlistment in the list of approved vendors of J.S.E.B. for supply of hardware for insulator, Conductor and Earth Wire accessories for our transmission line/ sub-stations both for direct supplies & for supply through turnkey contractors for three years.

This has got approval of Engineer-in-Chief.

Yours faithfully

  
(R. N. Tiwary)  
Chief Engineer (Transmission)



Phones : (022) 26598588 (O)  
(022) 26595130 (P)  
Fax : (022) 26598587

**Office of the Chief Engineer**  
(Projects & Design)  
Transmission Proj. Deptt.  
5<sup>th</sup> Floor, 'Prakashganga',  
Plot No. C-19, E-Block,  
Bandra Kurla Complex  
Bandra (E),  
MUMBAI - 400 051

Email : [ceprj@mahatransco.in](mailto:ceprj@mahatransco.in)

Ref.No. MSETCL/CO/D&E-L1/Vendor Approval/ 6759 Dt. 18.05.2012

To **M/s.A.K.Power Industries Pvt. Ltd**  
Shrutineer  
23/2/1/1, Bhagaban Chatterjee Lane  
Howrah -711101  
West Bangal

**Sub: Vendor Approval to M/s.A.K.Power Industries Pvt. Ltd. for manufacturing and supply of HDG transmission line towers, substation gantries and equipment support structures upto 220 KV Level for EPC/Turnkey/ORC/Wind Mill/Co Generation works.**

- Ref: 1) Lt.No. AKPIPL/MSETCL/PROJECT/EPC/APPROVAL/2011 dated 02.07.2011 M/s. M/s. A.K. Industries Pvt. Ltd  
2) T.O.Lt.No.MSETCL/CO./Tr.Proj./D&E-L1/Vendor Approval/10677 dated: 15.07.2011  
3) Lt.No. AKPIPL/MSETCL/PROJECT/APPROVAL/2012/01 dated 02.03.2012 from M/s. M/s. A.K.Power Industries Pvt. Ltd  
4) Lt.No. AKPIPL/MSETCL/PROJECT/APPROVAL/2012/04 dated 05.05.2012 from M/s. M/s. A.K.Power Industries Pvt. Ltd  
5) Lt.No. AKPIPL/MSETCL/PROJECT/APPROVAL/2012/06 dated 10.05.2012 from M/s. M/s. A.K.Power Industries Pvt. Ltd  
6) Lt.No. AKPI/MSETCL/L-215/12-13 dated 14.05.2012 from M/s.A.K.Power Industries Pvt. Ltd

Dear Sirs,

This has reference to your letter cited at reference (1) above, whereby you have submitted your credentials for vendor registration of your below mentioned plant (Unit I & II) for supply of **HDG transmission line towers, substation and equipment support structures upto 220 KV class**

**M/s.A.K.Power Industries Pvt. Ltd (Unit-I & II)**  
Howrah -Amta Road ,Kantalia, nibra  
Howrah -711409  
West Bangal

Based on the credentials submitted, **M/s.A.K.Power Industries Pvt. Ltd.** is recommended for approval as a vendor for supply of Substation structures and Transmission line towers upto 220 KV voltage class.; **for the works involving supply for transmission line towers, substation gantries and equipment support structures for EPC / Turnkey contracts/ORC works/Wind Mill Generation/ Cogeneration works. subject to the following conditions:**

Continue.....



## MAHARASHTRA STATE ELECTRICITY TRANSMISSION CO. LTD.

Phones : (022) 26598588 (O)  
(022) 26595130 (P)

**Office of the Chief Engineer (Proj. & Des.)**  
Trans. Project Department, 5<sup>th</sup> Floor,  
'Prakashganga', Plot No. C-19, E-Block,  
Bandra - Kurla Complex, Bandra (E),  
MUMBAI - 400 051

Fax : (022) 26598587  
E-mail : [ceprj@mahatransco.in](mailto:ceprj@mahatransco.in)

Ref. No.: MSETCL/CO/Tr. Proj./D&E-L2/Vendor Approval/6834 Date: 24/05/2012

To **M/s. A.K.Power Industries Pvt. Ltd,**  
23/2/1/1, Bhagaban Chatterjee Lane,  
Shrutineer, Howrah - 711 101  
Fax No. : (033) 26775147

**Sub: Approval as a vendor for supply of Insulator hardwares and conductor / earthwire Accessories thereof.**

- Ref: 1) Your L.No. AKPIPL/MSETCL/PROJECT/EPC/APPROVAL/2011 dt. 21.6.11.  
2) Our L.No. MSETCL/CO./D&E-L2/Vendor Approval/10003 dt. 4.7.2011  
3) Your L.No. AKPIPL/MSETCL/PROJECT/EPC/APPROVAL/2011/1 dt. 1.8.11.  
4) Our L.No. MSETCL/CO./D&E-L2/Vendor Approval/14121 dt. 19.9.2011  
5) Your L.No. AKPIPL/MSETCL/APPROVAL/2011-12 dt. 22.2.12.

Dear Sirs,

We refer to the letter cited under ref. (5) above, vide which you have forwarded your credentials for approval as vendor for supply of Insulator hardwares and conductor / earthwire Accessories. ....

Based on the documents submitted and clarifications/confirmations, we convey our acceptance to you as an approved vendor for supply of Insulator hardwares & Conductor/ Earthwire accessories **upto 220 KV, for all Transmission line and substation works** under EPC/Turnkey/ORC/IPP in Maharashtra.

**The above acceptance is subject to the followings:**

- The **1500 Ton** Horizontal Tensile Testing machine of **11 metre length shall be set-up by you at your works** for conducting Mechanical/Slip strength test on Compression type Tension Clamp, Suspension clamp with P.A.Rod, MSCJ and Repair Sleeve suitable for ACSR/AAA conductors.
- Factory inspection will be carried out by MSETCL's representative for verification of above testing equipment **before execution of 1<sup>st</sup> order by you.** You shall accordingly intimate the date to this office for deputing our representative for the verification.

**ODISHA POWER TRANSMISSION CORPORATION LIMITED**  
 (A Government of Odisha Undertaking)  
 Registered Office: Janpath, Bhubaneswar-751022  
**Telephone No. 0674-2541801 Fax No. 0674-2542964**  
 No.Sr. GM-CPC-IV-NEW VENDOR-02/2011/ 3133 /Dated. 11.05.2012

From  
 The Sr. General Manager (CPC),  
 OPTCL., Bhubaneswar.


To  
 M/s A.K. Power Industries Pvt Ltd.  
 Shrutineer,23/2,1/1, Bhagaban Chatterjee Lane,  
 Howrah-711101.

Sub: Regarding enlistment of your firm in the vendor list of OPTCL.

Dear Sir,  
 With reference to the subject, you are intimated that OPTCL have been pleased to enlist your firm in the vendor list for <sup>S/S Structure</sup> Transmission line Towers & accessories for the turn key projects.

Enlistment of your firm in the vendor list does not absolve you of the responsibility of maintaining the quality of, Transmission line Towers & accessories.

Yours faithfully,

  
**SR. GENERAL MANAGER (CPC)**

- C.C:
- 1) C.G.M. (O&M) OPTCL, Bhubaneswar.
  - 2) C.G.M. (Construction) OPTCL, Bhubaneswar
  - 3) Sr.G.M. (TP&C) OPTCL, Bhubaneswar

**ORISSA POWER TRANSMISSION CORPORATION LIMITED**  
 (A Government of Orissa Undertaking)  
 Registered Office: Janpath, Bhubaneswar-751022  
**Telephone No. 0674-2541801 Fax No. 0674-2542964**  
 No.Sr. GM-CPC-IV-NEW VENDOR-02/2011/ 9449(3) /Dated. 21.10.2011

From  
 The Sr. General Manager (CPC),  
 OPTCL., Bhubaneswar.

To  
 M/s A.K. Power Industries Pvt Ltd.  
 Shrutineer,23/2,1/1, Bhagaban Chatterjee Lane,  
 Howrah-711101.

Sub: Regarding enlistment of your firm in the vendor list of OPTCL.


Dear Sir,  
 With reference to the subject, you are intimated that OPTCL have been pleased to enlist your firm in the vendor list for Sub station Transmission line hardwares, Conductor accessories & earth wire accessories for the turn key projects.

Enlistment of your firm in the vendor list does not absolve you of the responsibility of maintaining the quality of Sub station, Transmission line hardwares, Conductor accessories & earth wire accessories.

Yours faithfully,

  
**SR. GENERAL MANAGER (CPC)**

- C.C:
- 1) C.G.M. (O&M) OPTCL, Bhubaneswar.
  - 2) C.G.M. (Construction) OPTCL, Bhubaneswar
  - 3) Sr.G.M. (TP&C) OPTCL, Bhubaneswar

	<b>Power Transmission Corporation of Uttarakhand Ltd.</b> <b>पावर ट्रांसमिशन कारपोरेशन ऑफ उत्तराखण्ड लि०</b> 7 - B, Lane - 1, Vasant Vihar Enclave Mob. 9837893749 Dehradun - 248001 Telefax - 0135-2763429 E-mail: anil_yadav@ptcul.org
No. <u>90</u> /SE(QA/QC)/PTCUL/A	Dated: 02/05/2012

M/s. A.K. Power Industries Pvt. Ltd.  
 Shrutineer, 22/2/1/1, Bhagaban Chatterjee Lane,  
 Howrah - 711101 (West Bengal)  
 Tel: 033 - 26775149/5152  
 E-mail: info@akpi.in

**Subject:- Regarding vendor approval for supply of Substation Structures upto 220 KV Projects & Transmission Line Towers upto 220 KV Projects in PTCUL.**

Dear Sir,  
 Please refer your letter no. AKPI/PTCUL12-13/01 dated 02.04.2012 for vendor registration in PTCUL for supply of Substation Structures, Transmission Line Towers & Hardware Fittings & Accessories. In this connection, your works were inspected on 24.04.2012 by undersigned and your credentials were evaluated. It is to inform you that your vendor registration has been accepted by PTCUL and you are being registered as a vendor for the supply Substation Structures upto 220 KV Projects & Transmission Line Towers upto 220 KV Projects in turnkey contracts and for participation in tenders for these items floated by PTCUL provided your company meets the PQR criteria of the respective floated tender. Your vendor registration has been accepted with following conditions:


1. Company will have to follow the rules and regulation laid down by PTCUL.
2. Company has to get the approval of MQP before commencement of their production and QAP before placing inspection call for supply of material.
3. This acceptance does not absolve you from your contractual liabilities of the respective tender.
4. The company has to procure raw material only from PTCUL approved sources/vendor.
5. Proto assembly of substation structures/transmission line towers is essential to proceed with mass fabrication. The design of tower if needed by Department as per agreement shall have to be duly type tested.

  
**(Anil Kumar)**  
**Superintending Engineer (QA/QC)**

No. - /SE(QA/QC)/PTCUL/  
 Copy forwarded to the following for kind information.

1. SE(Engg.), PTCUL H/Q Building, 132 KV S/s Majra, Dehradun.

  
**(Anil Kumar)**  
**Superintending Engineer (QA/QC)**


	<b>Power Transmission Corporation of Uttarakhand Ltd.</b> <b>पावर ट्रांसमिशन कारपोरेशन ऑफ उत्तराखण्ड लि०</b> 7 - B, Lane - 1, Vasant Vihar Enclave Mob. 9837893749 Dehradun - 248001 Telefax - 0135-2763429 E-mail: anil_yadav@ptcul.org
No. <u>90</u> /SE(QA/QC)/PTCUL/B	Dated: 02/05/2012

M/s. A.K. Power Industries Pvt. Ltd.  
 Shrutineer, 22/2/1/1, Bhagaban Chatterjee Lane,  
 Howrah - 711101 (West Bengal)  
 Tel: 033 - 26775149/5152  
 E-mail: info@akpi.in

**Subject:- Regarding vendor approval for supply of Hardware Fittings & Accessories for Transmission Line Tower upto 220 KV Projects & Substation Structure upto 220 KV Projects in PTCUL.**


Dear Sir,  
 Please refer your letter no. AKPI/PTCUL12-13/01 dated 02.04.2012 for vendor registration in PTCUL for supply of Substation Structures, Transmission Line Towers & Hardware Fittings & Accessories. In this connection, your works were inspected on 24.04.2012 by undersigned and your credentials were evaluated. It is to inform you that your vendor registration has been accepted by PTCUL and you are being registered as a vendor for the supply Hardware Fittings & Accessories for Transmission Line Tower upto 220 KV Projects & Substation Structure upto 220 KV Projects in turnkey contracts and for participation in tenders for these items floated by PTCUL provided your company meets the PQR criteria of the respective floated tender. Your vendor registration has been accepted with following conditions:

1. Company will have to follow the rules and regulation laid down by PTCUL.
2. Company has to get the approval of MQP before commencement of their production and QAP before placing inspection call for supply of material.
3. This acceptance does not absolve you from your contractual liabilities of the respective tender.
4. The company has to procure raw material only from PTCUL approved sources/vendor.
5. Hardware Fittings & Accessories of every type design which shall be supplied shall have to be duly type tested then only MQP shall approved.

  
**(Anil Kumar)**  
**Superintending Engineer (QA/QC)**

No. /SE(QA/QC)/PTCUL/  
 Copy forwarded to the following for kind information.

1. SE (Engg.), PTCUL H/Q Building, 132 KV S/s Majra, Dehradun.

  
**(Anil Kumar)**  
**Superintending Engineer (QA/QC)**



**WEST BENGAL STATE ELECTRICITY TRANSMISSION COMPANY LIMITED**  
 (A Govt. of West Bengal Enterprise)  
**OFFICE OF THE CHIEF ENGINEER ENGINEERING DEPARTMENT**  
**VIDYUT BHAVAN, 9TH FLOOR D - BLOCK**  
**SALT LAKE CITY KOLKATA - 700 091**  
**PHONE: (033) 2321 6772 FAX: (033) 2334 5961**  
**E-mail : ceed10@yahoo.in**

WBSETCL

Memo No. CE/Engg/ Insp/ 195

Dated 13/09/12

To  
 M/S A.K. Power Industries Pvt. Ltd.  
 Shrutineer, 23/2/1/1, Bhagaban Chatterjee Lane  
 Howrah-711101

Sub- Provisional approval of vendors for supply of Fabricated GI Members for Substation Structures.

Ref.: 1) Your letter AKPI / WBSETCL /11-12 /2181 dt.27.03.12

Dear Sir

This has reference to your letter mentioned above. Based on the credentials alongwith related documents submitted by you and subsequent inspection to your factory premises, we hereby convey our provisional approval in favour of you for supply of fabricated galvanized structural members through our Working Turnkey Contractors for the Sub-Station under construction. This provisional approval will be valid for one year from the date of issue of this letter.

However, all the items shall meet the requirement of WBSETCL technical specification & relevant IS codes as per contracts. Raw materials should be procured from main producers viz. SAIL/RINL/TISCO/ISCO. BIS certificates and ISO certificates should remain valid and to be produced within a short notice to this end if asked for. If at any point of time, any abnormality is noticed, we reserve the right to withdraw this approval with immediate effect.

Yours Sincerely  
  
 (S. Bhattacharya)  
 Chief Engineer, Engg. Deptt.

 UPPTCL BPPCTCL	कार्यालय अधीकरण अभियन्ता विद्युत परीक्षण परिष्करण मण्डल उच्च वोल्टेज ट्रांसमिशन कारपोरेशन लि. राक्षस भवन बिल्डिंग, १०वीं फ्लोर, १४-अशोक मार्ग, लखनऊ- २२६ ००१ (भारत)	Office of the superintending Engineer Elect Transmission Design Circle (UP GOVERNMENT UNDERTAKING) Shakti Bhawan Bldg., 10 <sup>th</sup> Floor, 14-Ashok Marg, Lucknow-226 001 (INDIA) Tele: 0522-2287701 Ext. 4555 Fax: 0522-2287872
-----------------------	---	--

No 3100 /ETDC/2/ General

Dated 15.9.12

Sub- Vendor approval for supply of Hardwares and accessories of ACSR Zebra, Panther & Earthwire

M/s Aravali Infrapower Ltd.  
 G-29, 3<sup>rd</sup> Floor vardhman tower  
 Community center vikas puri  
 New Delhi-110018

Sirs,

Please refer to your letter-PT-13/TD-348/UPPTCL/2039 dated 21.11.11 and PT-30/TD-348/UPPTCL/AJ/F1/3051 dated 06.06.12 vide which you have requested for vendor approval of M/s A.K Power industries Pvt Ltd, Howrah, for purchase of Hardwares and accessories of ACSR Zebra/ Panther/ earthwire for 132/220 kV lines being constructed by you against the tender.

After analysing various documents attached with the profile of the firm submitted by you, and inspection of work of the vendor you are being authorised to purchase hardwares and accessories of ACSR Zebra/ Panther/ earthwire from M/s A.K Power industries Pvt Ltd, Howrah on trial basis, initially for one year, which may be further extended after ascertaining the quality and performance of the material. "However order for Hardware of Earthwire shall be placed to the firm only after they submits type test of the same"

It shall be your sole responsible that materials are supplied in accordance with relevant IS /UPPTCL's approved GTP. Kindly submit detailed QAP, drawings and GTP of Hardware and accessories for approval

Material shall be dispatched after inspection of material by UPPTCL officers. Even after inspections, you shall be solely responsible for the quality of material and shall ensure that materials is supplied as per approved GTP and drawings and ISS, failing which the material shall be rejected at your's risk and responsibility and approval shall be revoked . If any material is found defective/substandard you

SE ETDC  
 17/9/12  
 No. 2208  
 Date: 18.9.12  
 C.E. (D&P)

**Bihar State Power Transmission Company Ltd., Patna**  
 (A successor company of BSEB)

Letter No. ....1643... / BSPTCL,  
 27/Misc/Trans/167/2013

Patna Dated....16-7-12

From, Sri Y.K. Thakur,  
 Chief Engineer (Transmission).

Fax No. 0612-2504655

To, M/s Chauhan & Co.,  
 Branch Office, H/O - Prof. D. Rai  
 Azad Nagar, Road No-1,  
 School Campus,  
 Lohiya Nagar, Kankarbagh,  
 Patna - 800020.

Sub- Vender approval.

Ref- (i) N.I.T. No. 110/PR/BSPTCL/2013.  
 (ii) LOI No. 1481 & 1482 both dated 01.07.2013.  
 (iii) Your letter No. C&Co/BSPTCL/400/13-14/24 dated 12.07.2013.

Dear Sir,  
 With reference to above, this is to inform that your request for according vender approval of make M/s A.K. Power Industries Ltd., Howrah for fabrication, supply of 400 KV S/C tower having its weight in totalling about 200 MT pertaining to restoration of Biharsharif-TTPS Transmission line is approved with a condition that steel required for fabrication of said tower material shall be of the roller - TISCO, VSP, SAIL, ISCO & Swastika Steel & Allied Products (P) Ltd., Kolkata for which approved test report has been enclosed with your letter under reference.

The tower structure etc. shall be manufactured & supplied as per IS code and per approved BOM / Structural Drawing etc.

It may please be noted that approval of aforesaid vender does not absolve you from contractual responsibility in terms of quality & correctness of material.

Immediate action in this regard is hereby requested to restore the line within the completion schedule.

Yours faithfully,  
  
 (Y.K. Thakur)  
 Chief Engineer (Transmission)

**STERLITE GRID LIMITED**

C-2, Mira Corporate Suit,  
 Ishwar Nagar, New Delhi 110 065  
 Phone: +91-11-4996 2200, Fax: +91-11-4996 2288  
 www.sterlitegrid.com

Ref: QAC-SGL-VAL-0002

Date: 30-Dec-2013

To, M/s A.K Power Industries (P) Limited  
 "Shrutineer Apartment" 1st Floor 23/2/1/1,  
 Bhagaban Chatterjee Lane, Howrah - 71101.

Kind Attention: Mr. Mrinmoy Mitra

Sub: Fabrication plant approval.

With reference to the above subject and to your request for approval of your fabrication plant (M/s AK Power Industries (P) Limited, Howrah Amta Road, Makardah, Kantalia, Nibra, Howrah - 711009) for supply of transmission line & substation galvanized structure for our 400kV projects in India, we hereby convey our approval subject to following conditions:

- Manufacturing process shall be followed as per our MQP (SMQP/01, Rev-03 & Valid up to 08<sup>th</sup> Feb 2015).
- Raw materials shall be procured only from vendors that have already been approved:
  - Prime Sources:
    - M/s SAIL
    - M/s RINL
    - M/s TISCO
    - M/s ISCO
    - M/s Adhunik Metals Ltd.
  - Plates:
    - M/s Essar Steel Ltd., 27km, Surat Hazira Road, Hazira, Surat for HT & MS Plates.
    - M/s JSW Steel Ltd., P.O. Toranagalla, Distt: Bellary, Karnataka for supply of MS & HT Plates from 3mm to 10mm.
    - M/s JSW Steel Ltd., Tarapur MIDC - Boisar, Dist.: Thane for the supply of MS & HT Plates of size 8mm & above.
    - M/s Llyods Steel, Wardha for the supply of MS Plates.
    - M/s SAIL
  - Re-Rollers:
 

As per SGL Approved List and they shall roll the material in-line with requirement of IS-2062. SGL-MS & SGL-HT marking should be embossed on the all sections.
- The subject approval shall be valid from the date of issue of this letter up to 31-Dec-2014 and subject to renewal after Dec-2014 with assessment / review of performance & quality.

Please note that the materials shall meet the requirements of SGL technical specification/drawing/data sheets. If at any point of time, any abnormality or deviation from specification is noticed in this regard, SGL reserves the right to withdraw this approval with immediate effect.

For Sterlite Grid Ltd.

Author  
  
 (Q&A Deptt.)

Registered office: C-2, Mira Corporate Suit, Ishwar Nagar, New Delhi - 110 065

